



## Information Bulletin:

### Revised ES54 S0-04 Secondary Services General Notes

#### 1.0 Items Covered

ES54 S0-04 R4 Secondary Services General Notes

The standard listed above can be found at [bchydro.com/distributionstandards](http://bchydro.com/distributionstandards).

#### 2.0 Overview

ES54 S0-04 has been revised to R4. The changes are described in the following table:

Page	Section	Changes
5	Note 3.3(c) Customer-Owned Transformation Up to 34.5 kV Primary Service	Updated the current rating from 1600 A to 800 A.
5	Note 4.1(b) Wireways and Pull Boxes Utility Wireway	Clarified 1.5 m minimum clearance requirements in front of wireways and pull boxes.

#### 3.0 Action

ES54 S0-04 R4 is effective immediately.

##### Designers, Engineers, and Civil Inspectors

Designers, engineers, and civil inspectors should familiarize themselves with ES54 S0-04 R4.

##### Customer and Customer Representatives

Customers and customer representatives, including electricians, project managers, consultants, and contractors, should familiarize themselves with ES54 S0-04 R4.

#### 4.0 Contact

##### Customer and Customer Representatives

Please direct questions and concerns to your local BC Hydro representative.

**BC Hydro Employees and Contractors**

Please direct questions and concerns related to the standard to  
[distribution.standards@bchydro.com](mailto:distribution.standards@bchydro.com).

**Prepared by:** Braedon Linforth

**Date:** 2025-12-16