

6911 Southpoint Drive (B03)  
Burnaby, BC  
V3N 4X8

July 30, 2024

[REDACTED]  
[REDACTED]  
[REDACTED]  
[REDACTED]  
[REDACTED]  
[REDACTED]

**RE: CEAP IR 106 - Williams Lake Solar Project - Interconnection Feasibility Study Report**

Enclosed is the Interconnection Feasibility study report for the proposed Williams Lake Solar Project submitted under Attachment M-2: Transmission Service and Interconnection Service Procedures for Competitive Electricity Acquisition Process (CEAP) of the Open Access Transmission Tariff (OATT). This letter provides a non-binding good faith estimate of the cost and time to construct the facilities required to interconnect your project to BC Hydro's Transmission System, being the Network Upgrades, based on the findings of the Interconnection Feasibility study.

**Open Access Transmission Tariff**

The OATT defines Network Upgrades as additions, modifications, and upgrades to BC Hydro's Transmission System required at or beyond the Point of Interconnection to accommodate the interconnection of the Generating Facility to the BC Hydro's Transmission System. Pursuant to the OATT, BC Hydro will design, procure, construct, install, and own the Network Upgrades. While BC Hydro will pay the costs for the Network Upgrades, the Interconnection Customer provides security for such costs.

**Cost Estimate**

Based on the Interconnection Feasibility study, the non-binding good faith estimated cost (typical accuracy range of +150%/-50%) for Network Upgrades required to interconnect your project is \$62.6 M.

**Major Scope of Work Identified:**

- Expand the substation and extend the existing 230 kV bus structure at BC Hydro Soda Creek (SCK) substation
- Add one 230kV line position with the associated substation equipment at SCK
- Add one switched shunt reactor of 75 MVAR 230kV at SCK for the system voltage support under single contingency operation
- Supply and install one rack, fibre patch panel, and all dielectric fibre entrance cable
- Supply and install protection relays and other required protection equipment
- Supply and install two digital teleprotection circuits and connect to protective equipment
- Other Telecom and Protection work, as required

**Exclusions:**

- GST
- Right-of-Way
- Permits

**Key Assumptions:**

- Construction by contractor
- 3 years of construction
- No station expansion is required
- No ground improvements for crossing towers are required

**Key Risks:**

- Expansion of the existing control building may be required leading to increased costs and/or a longer project schedule
- No defined supply chain strategy, construction costs may increase depending on delivery method
- Project schedule may be longer than expected, leading to increased costs
- Costs may be affected by market conditions and escalation

Please note that the Revenue Metering requirements and associated costs required to interconnect your project have not been determined at this stage and, therefore, not included in the above estimate. Revenue Metering costs that are attributable to the Interconnection Customer are to be paid in cash. For more details on Revenue Metering requirements and responsibilities, please refer to:

<https://www.bchydro.com/content/dam/BCHydro/customer-portal/documents/distribution/standards/ds-rmr-complex-revenue-metering.pdf>.

**Schedule**

Based on the Interconnection Feasibility study, the non-binding good faith estimated in-service date for your project's Network Upgrades is Quarter 3, 2031 (calendar year). To achieve this timeline, we may need to expedite certain activities, including engineering design and procurement of long-lead equipment.

Timely actions required from you to minimize risks to the schedule:

- Submission of additional technical data required for the System Impact Study and Facilities Study
- Submission of any required information or document such as demonstration of Site Control
- Execution of Combined Study Agreement and Standard Generator Interconnection Agreement
- Financial commitments and securities


Please note that changes to your interconnection request, delays in data submission, or financial commitments may also impact the target in-service date.

**Next Steps**

In September 2024, we will issue a final invoice for the Feasibility Study costs. This invoice will reflect the total amount due, taking into account the \$15,000 Feasibility Study deposit you have already paid and any remaining amount on the non-refundable \$15,000 Interconnection request deposit that we did not spend in reviewing and validating your interconnection request.

If you have any questions, please contact the BC Hydro CEAP Team at [ceap2024@bchydro.com](mailto:ceap2024@bchydro.com).

Sincerely,



Senior Manager, Transmission Interconnections

BC Hydro

Encl.: CEAP2024\_IR\_106\_Williams Lake Solar\_FeS\_Report\_final.pdf




# Williams Lake Solar Project

## Interconnection Feasibility Study

**BC Hydro EGBC Permit to Practice No: 1002449**

**2024 CEAP IR # 106**


Prepared for:





## Report Metadata

Header: Williams Lake Solar Project  
Subheader: Interconnection Feasibility Study  
Title: Williams Lake Solar Project  
Subtitle: 2024 CEAP IR # 106  
Report Number: 850-APR-00014  
Revision: 0  
Confidentiality: Public  
Date: 2024 Jul 30  
Volume: 1 of 1



Related Facilities: Soda Creek Substation (SCK), 2L352, 2L94, 2L95  
Additional Metadata: Transmission Planning 2024-106  
Filing Subcode 1350



## Revisions

| Revision | Date     | Description     |
|----------|----------|-----------------|
| 0        | 2024 Jul | Initial release |



## Disclaimer of Warranty, Limitation of Liability

This report was prepared solely for internal purposes. All parties other than BC Hydro are third parties.

BC Hydro does not represent, guarantee or warrant to any third party, either expressly or by implication:

any information, product or process disclosed, described or recommended in this report.

BC Hydro does not accept any liability of any kind arising in any way out of the use by a third party of any information, product or process disclosed, described or recommended in this report, nor does BC Hydro accept any liability arising out of reliance by a third party upon any information, statements or recommendations contained in this report. Should third parties use or rely on any information, product or process disclosed, described or recommended in this report, they do so entirely at their own risk.

This report was prepared by the British Columbia Hydro And Power Authority ("BCH") or, as the case may be, on behalf of BCH by persons or entities including, without limitation, persons or entities who are or were employees, agents, consultants, contractors, subcontractors, professional advisers or representatives of, or to, BCH (individually and collectively, "BCH Personnel").

This report is to be read in the context of the methodology, procedures and techniques used, BCH's or BCH's Personnel's assumptions, and the circumstances and constraints under which BCH's mandate to prepare this report was performed. This report is written solely for the purpose expressly stated in this report, and for the sole and exclusive benefit of the person or entity who directly engaged BCH to prepare this report. Accordingly, this report is suitable only for such purpose, and is subject to any changes arising after the date of this report. This report is meant to be read as a whole, and accordingly no section or part of it should be read or relied upon out of context.

Unless otherwise expressly agreed by BCH:

- (a) any assumption, data or information (whether embodied in tangible or electronic form) supplied by, or gathered from, any source (including, without limitation, any consultant, contractor or subcontractor, testing laboratory and equipment suppliers, etc.) upon which BCH's opinion or conclusion as set out in this report is based (individually and collectively, "Information") has not been verified by BCH or BCH's Personnel; BCH makes no representation as to its accuracy or completeness and disclaims all liability with respect to the Information;
- (b) except as expressly set out in this report, all terms, conditions, warranties, representations and statements (whether express, implied, written, oral, collateral, statutory or otherwise) are excluded to the maximum extent permitted by law and, to the extent they cannot be excluded, BCH disclaims all liability in relation to them to the maximum extent permitted by law;
- (c) BCH does not represent or warrant the accuracy, completeness, merchantability, fitness for purpose or usefulness of this report, or any information contained in this report, for use or consideration by any person or entity. In addition, BCH does not accept any liability arising out of reliance by a person or entity on this report, or any information contained in this report, or for any errors or omissions in this report. Any use, reliance or publication by any person or entity of this report or any part of it is at their own risk; and
- (d) In no event will BCH or BCH's Personnel be liable to any recipient of this report for any damage, loss, cost, expense, injury or other liability that arises out of or in connection with this report including, without limitation, any indirect, special, incidental, punitive or consequential loss, liability or damage of any kind.

## Copyright Notice

Copyright and all other intellectual property rights in, and to, this report are the property of, and are expressly reserved to, BCH. Without the prior written approval of BCH, no part of this report may be reproduced, used or distributed in any manner or form whatsoever.









## Executive Summary

██████████ the interconnection customer (IC), requests to interconnect its Williams Lake Solar Project (2024 CEAP IR # 106) to the BC Hydro (BCH) system. Williams Lake Solar Project has fifty (50) ██████████ solar inverter model, adding a total capacity of 200 MW into the BC Hydro system. The proposed Point of Interconnection (POI) is at the 230 kV bus of the BC Hydro's Soda Creek substation (SCK). The IC's project will connect to the POI via a customer built 130 km 230 kV interconnection line. The IC's proposed commercial operation date (COD) is Oct 1, 2028.

To interconnect the Williams Lake Solar Project and its facilities to the BCH Transmission System at the proposed POI, this Feasibility Study has identified the following conclusions and requirements:

1. A new 230 kV line position at SCK is required to interconnect the IC's generating project to the BC Hydro system.
2. The connection of Williams Lake Solar Project caused a potential voltage performance issue. A new 75 MVar 230 kV switched shunt reactor with AutoVar control scheme is required to be installed at the Soda Creek substation 230 kV bus to mitigate the potential issue. The size of the reactor will be further tuned in subsequent studies.
3. In addition to entrance protection and 2LXX line protection, the IC is required to install anti-islanding protection within their facility to disconnect the solar farm from the grid when an inadvertent island with the local loads forms.
4. According to BC Hydro's TIR, the IC's project must have sufficient reactive power capability over full MW operating range including at the zero MW output level. The Williams Lake Solar farm as submitted does not meet the reactive capability requirement which will need to be addressed.
5. BC Hydro will provide line protection for new line between BC Hydro SCK substation and IC's Williams Lake Solar (P106) substation (BC Hydro end only). As part of the line protection for the new line, telecommunication facilities will be required between the two terminals to accommodate the new protection schemes. In addition, protection upgrades are required at SCK substation for the new 230 kV bus and the new shunt reactor 2RX1.



The IC shall provide required relays, telecom facility and associated equipment at its facilities to accommodate the new protection schemes.

The above conclusions are made based on the IC's input data and study assumptions listed in Section 4, which represent the best available information on May 22, 2024.

A non-binding good faith estimated cost and time to construct the Network Upgrades required to interconnect the proposed project will be provided in a separate letter to the IC.



# Contents

|  |            |
|--|------------|
| <b>Executive Summary</b>                   | <b>vii</b> |
| <b>1 Introduction</b>                      | <b>12</b>  |
| <b>2 Purpose and Scopes of Study</b>       | <b>14</b>  |
| <b>3 Standard and Criteria</b>             | <b>15</b>  |
| <b>4 Assumptions and Conditions</b>        | <b>16</b>  |
| <b>5 System Studies and Results</b>        | <b>17</b>  |
| 5.1 Power Flow Study Results               | 17         |
| 5.1.1 Branch Loading Analysis              | 17         |
| 5.1.2 Steady-State Voltage Analysis        | 18         |
| 5.1.3 Reactive Power Capability Evaluation | 18         |
| 5.1.4 Anti-Islanding Requirements          | 19         |
| 5.2 Fault Analysis                         | 19         |
| 5.3 Stations Requirements                  | 19         |
| 5.4 Protection & Control Requirements      | 20         |
| 5.5 Telecommunications Requirements        | 20         |
| <b>6 Cost Estimate and Schedule</b>        | <b>22</b>  |
| <b>7 Conclusions</b>                       | <b>23</b>  |

## Appendices

|            |  |
|------------|--|
| Appendix A | Plant Single Line Diagram Used for Power Flow Study                      |
| Appendix B | One-Line Sketch for Addition of a 230 kV Line Position at SCK Substation |



## Acronyms

The following are acronyms used in this report.

|      |  |
|------|--|
| BCH  | BC Hydro   |
| SCK  | BC Hydro Soda Creek Substation   |
| CEAP | Competitive Electricity Acquisition Process  |
| COD  | Commercial Operation Date  |
| DTT  | Direct Transfer Trip   |
| ERIS | Energy Resource Interconnection Service  |
| FeS  | Feasibility Study  |
| FVO  | Fraser Valley Office   |
| IBR  | Inverter-Based Resources   |
| IC   | Interconnection Customer   |
| LAPS | Local Area Protection Schemes  |
| MPO  | Maximum Power Output   |
| NERC | North American Electric Reliability Corporation  |
| NRIS | Network Resource Interconnection Service   |
| OATT | Open Access Transmission Tariff  |
| POI  | Point of Interconnection   |
| RAS  | Remedial Action Scheme   |
| SIO  | South Interior Office  |
| TIR  | BC Hydro “60 KV to 500 kV Technical Interconnection Requirements for Power Generators” |
| WECC | Western Electricity Coordinating Council   |



# 1 Introduction

Table 1-1 below summarizes the project reviewed in this Feasibility Study.

Table 1-1 Summary of Project Information

|   |   |                               |
|---|---|-------------------------------|
| Project Name  | Williams Lake Solar Project                   |                               |
| Name of Interconnection Customer (IC)   | [REDACTED]                                    |                               |
| Point of Interconnection (POI)  | 230 kV bus of the BCH's Soda Creek Substation |                               |
| IC's Proposed COD   | 1st October 2028                              |                               |
| Type of Interconnection Service   | NRIS <input checked="" type="checkbox"/>      | ERIS <input type="checkbox"/> |
| Maximum Power Injection <sup>1</sup> (MW)   | 200 MW (Summer)                               | 200 MW (Winter)               |
| Number of Generator Units   | 50 x 4.0 MW                                   |                               |
| Plant Fuel  | Solar   |                               |
| Note 1: The maximum achievable power injection at the POI is approx. 190.6 MW after accounting for MW losses and service load which is lower than the IC proposed 197.5 MW. |   |                               |

[REDACTED] the interconnection customer (IC), requests to interconnect its Williams Lake Solar Project (2024 CEAP IR # 106) to the BC Hydro (BCH) system. Williams Lake Solar Project has fifty (50) [REDACTED] solar inverter model, adding a total capacity of 200 MW into the BC Hydro system. The proposed Point of Interconnection (POI) is at the 230 kV bus of the BC Hydro's Soda Creek substation (SCK). The IC's project will connect to the POI via a customer built 130 km 230 kV interconnection line. The IC's proposed commercial operation date (COD) is Oct 1, 2028.

Figure 1-1 shows the Central Interior Regional transmission system diagram. The Central Interior regional transmission system is supplied from three 230 kV lines. One is from Williston (WSN) substation in the North (2L96) and two (2L86 and 2L94) are from Kelly Lake (KLY) in the South. The two main 230 kV substations in the middle of the region include Soda Creek substation (SCK) and BLW.




Figure 1-1: Central Interior Regional Transmission System Diagram in 2024 with the Proposed Williams Lake Solar Project Interconnection



## 2 Purpose and Scopes of Study

This Feasibility Study is a preliminary evaluation of the system impact of interconnecting the proposed project to the BC Hydro system based on power flow and short circuit analysis in accordance with BCH's Open Access Transmission Tariff (OATT). A non-binding good faith estimated cost of required Network Upgrades and estimated time to construct will be provided.

Per OATT, the Feasibility Study is performed individually for each of the participating projects in the CEAP and focuses specifically on the BC Hydro regional transmission system where the proposed generating project is proposed to be constructed. An assessment of the incremental effect on the 500kV bulk transmission system is beyond this study scope.

This is a "limited scope" study which is restricted to power flow studies of P0, P1 and P2 planning events as defined in TPL-001-4 and short circuit analysis. The study does not address other technical aspects such as transient stability and switching transients and impact of multiple contingencies. These subjects would be addressed in subsequent System Impact Study if the project is a Successful Participant of the CEAP.

In case impact to the adjacent external systems to BC Hydro is observed, such impact would be addressed in subsequent detailed and coordinated studies with the relevant adjacent entities if the proposed interconnection proceeds further.

### 3 Standard and Criteria

The Feasibility Study is performed in compliance with the North American Electric Reliability Corporation (NERC) and Western Electricity Coordinating Council (WECC) reliability standards, and the BCH interconnection requirements in the TIR, and upon the ratings of the existing BCH transmission facilities described in Operating Orders, specifically:

- NERC standards: TPL-001-4 and FAC-002-3 relevant to the scope of this Feasibility Study.
- WECC criteria TPL-001-WECC-CRT-4 Transmission System Planning Performance, July 1, 2023.
- BC Hydro's 60 kV to 500 kV Technical Interconnection Requirements for Power Generators.
- BC Hydro Operating Order 5T-10, Ratings for All Transmission Circuits 60 kV or Higher, April 16, 2024.
- BC Hydro Operating Order 5T-14, Ratings for All Transmission and Distribution Transformer, November 8, 2022.
- BC Hydro System Operating Order 7T-22 System Voltage Control, September 19, 2023.

## 4 Assumptions and Conditions

This Feasibility Study is performed based on the IC's submitted data and information available to BC Hydro on May 22, 2024 for the study purpose. Appendix A shows the plant single line diagram for the IC's project used in the study model. Certain assumptions were, as set out below, made to the extent required.

The power flow study cases used in this Feasibility Study are established based upon the BC Hydro's base resource plan and load forecasts available at the time of performing the study, which includes existing and future generations, transmission facilities, and loads in addition to the subject interconnection project in this study. Applicable seasonal conditions and the appropriate study years for the study planning horizon are also incorporated.

Additional assumptions are listed as follows.

- 1) The regional generation are dispatched to the patterns that stress the transmission system in the study area. In these patterns, the regional generations are typically set to their Maximum Power Outputs (MPO) unless otherwise specified.

## 5 System Studies and Results

The proposed customer-built 230 kV line (SCK-P106) will be designated as 2LXX and will become IC's BES and the IC will be responsible for the compliance with applicable MRS requirements. The temporary line designations will be replaced by permanent designations at a later stage of interconnection study.

### 5.1 Power Flow Study Results

Power flow studies were performed to evaluate whether the IC's generating project would cause any unacceptable system performance (e.g. equipment overloads, steady-state voltage violation and voltage instability) and to determine the reinforcement requirement based on steady state performance analysis.

The study focuses on the 2029 light summer (29LS) system load condition which is typically a stressed condition for a generation interconnection project, taking into considerations of factors such as load conditions, seasons and generation patterns. The 2029 heavy summer (29HS) and 2028 heavy winter (28HW) cases are also checked at a high level to capture any possibility of performance violations under high load conditions.

#### 5.1.1 Branch Loading Analysis

For all the studied load conditions, there is no branch overload identified under system normal condition (P0) and single contingency conditions (P1 and P2). Table 5-1 below shows the loadings on existing lines 2L354 and 2L96 with IC at maximum output.

Table 5-1: Summary of Branch Loading

| Case | Contingency |               | Branch Loading |      |       |
|------|-------------|---------------|----------------|------|-------|
|      | Category    | Description   | 2L95           | 2L94 | 2L352 |
| 28HW | P0          | System Normal | 7%             | 21%  | 15%   |
|      | P1          | 2L95          | na             | 24%  | 16%   |
|      | P1          | 2L94          | 13%            | na   | 22%   |
|      | P1          | 2L352         | 15%            | 33%  | na    |
| 29HS | P0          | System Normal | 16%            | 33%  | 15%   |
|      | P1          | 2L95          | na             | 41%  | 19%   |
|      | P1          | 2L94          | 28%            | na   | 25%   |

|      |    |               |     |     |     |
|------|----|---------------|-----|-----|-----|
|      | P1 | 2L352         | 29% | 51% | na  |
| 29LS | P0 | System Normal | 35% | 29% | 14% |
|      | P1 | 2L95          | na  | 45% | 20% |
|      | P1 | 2L94          | 48% | na  | 20% |
|      | P1 | 2L352         | 46% | 42% | na  |

### 5.1.2 Steady-State Voltage Analysis

A potential high voltage issue has been observed under light load condition caused by Williams Lake Solar project under single contingency condition.

A new 75 MVar 230 kV switched shunt reactor with AutoVar control scheme is required to be installed at the Soda Creek substation 230 kV bus to mitigate the potential high voltage issue. The size of the reactor will be further tuned in subsequent studies.

Table 5-2: Summary of Steady-State Voltage Study Results

| Case | IPP's Generator Output | Contingency |             | Bus Voltage (P.U.) |          |          |
|------|------------------------|-------------|-------------|--------------------|----------|----------|
|      |                        | Cate-gory   | Description | RBF 230            | SCK 230  | KLY 230  |
| 29LS | 0 MW                   | P1          | 2L354       | 1.104 PU           | 1.102 PU | 1.071 PU |
| 32LS | 0 MW                   | P1          | 2L354       | 1.105 PU           | 1.103 PU | 1.070 PU |

### 5.1.3 Reactive Power Capability Evaluation

The BC Hydro TIR requires IBR power plant to have the dynamic reactive power capability at a minimum of +/- 33% of its MPO at the high voltage side of the IC's switchyard over the full MW operating range.

Based on the PSS/E power flow data submitted by the IC, the proposed generating project would not be capable of meeting the BC Hydro's reactive capability requirement at the plant's maximum MW output, which is subjected to further verification in the next stage of interconnection study. Installation of reactive power equipment is required at the customer facility to meet the requirement.

Furthermore, the BCH TIR requires the IC's project to provide sufficient reactive power capability over full MW operating range including at zero MW output level. The proposed solar farm does not meet this requirement at near zero MW output, which will need to be addressed.

#### **5.1.4 Anti-Islanding Requirements**

The IC is required to install anti-islanding protection within its facility to disconnect the IC's solar farm from the grid when an inadvertent island with the local load forms.

### **5.2 Fault Analysis**

The short circuit analysis in the FeS is based upon the latest BC Hydro system model, which includes the generating facility information and associated impedance data provided by the IC. A more detailed study will be performed at the system impact study stage if needed.

### **5.3 Stations Requirements**

The station upgrade scope at the existing Soda Creek substation is as follows.

- Expand the substation and extend the existing 230 kV bus structure.
- Add one 230kV line position with the associated substation equipment. Refer to one line diagram in Appendix B for details.
- Add one switched shunt reactor of 75 MVAR 230 kV for system voltage control.
- Expand the existing control building, if required, to accommodate the new P&C panels and other equipment.
- Terminate the Williams Lake Solar Project line.
- Other associated station work.

Following assumptions are made related to Station scope of work.

- There are no issues for the acquisition of the property on the west side of the substation, required for the expansion.
- The creek on the west side of the station can be mitigated for the 230kV bus structure design and installation; no civil engineering issues.

- There are no archeological findings that could impede with the station expansion.
- The high elevation differential on the West side of the station can be mitigated with appropriate technology for the bus solution (to be investigated in the next stage).

## 5.4 Protection & Control Requirements

For successful integration of the new solar farm, BC Hydro will provide line protections for 2LXX at BC Hydro's SCK Substation. As part of the line protection addition, telecommunication facilities will be required between SCK substation and Williams Lake Solar (P106). In addition, protection upgrades are required at SCK substation for the new 230 kV bus and the new shunt reactor 2RX1.

The IC is to provide the following for the interconnection of Williams Lake Solar project.

- Entrance protection that complies with the latest version of the "60 kV to 500 kV BC Hydro Technical Interconnection Requirements for Power Generators."
- Provide two SEL-411L-1 relays (firmware and options specified by BC Hydro) relays at the entrance of Williams Lake Solar (P106) to provide protection coverage for 2LXX. BC Hydro P&C Planning will provide core protection settings for these relays to protect transmission line 2LXX from SCK to the IC during a transmission line fault. Non-core protection such as local breaker failure, auto-reclosing, backup protection for station elements will not be provided by BC Hydro P&C Planning.
- The IC is responsible for NERC PRC-related tasks, settings to compliance standards within their facilities.
- The IC is responsible for providing a communications link for remote interrogation of the line protection relays and PPIS equipment by BCH servers.
- Provide anti-islanding protection as stated in Section 5.1.

## 5.5 Telecommunications Requirements

BC Hydro performed a high-level feasibility assessment of a telecom solution to meet the following requirements.

### **Teleprotection Requirements for Telecom**

- WECC Level 3 PY & SY, SCK – P106, with C37.94 interfaces.

### **Telecontrol Requirements for Telecom**

- One P106 SCADA circuits to FVO and SIO.

Certain assumptions were made for determining a potential telecom solution. Details of the telecom solution (e.g. assumptions made, alternatives investigated and work required for BCH and the IC) would be provided at the next study stage.



## 6 Cost Estimate and Schedule

A non-binding good faith estimated cost and time to construct the Network Upgrades required to interconnect the proposed project will be provided in a separate letter to the IC.

## 7 Conclusions

To interconnect the Williams Lake Solar Project and its facilities to the BCH Transmission System at the proposed POI, this Feasibility Study has identified the following conclusions and requirements:

1. A new 230 kV line position at SCK is required to interconnect the IC's generating project to the BC Hydro system.
2. The connection of Williams Lake Solar Project caused a potential voltage performance issue. A new 75 MVar 230 kV switched shunt reactor with AutoVar control scheme is required to be installed at the Soda Creek substation 230 kV bus to mitigate the potential issue. The size of the reactor will be further tuned in subsequent studies.
3. In addition to entrance protection and 2LXX line protection, the IC is required to install anti-islanding protection within their facility to disconnect the solar farm from the grid when an inadvertent island with the local loads forms.
4. According to BC Hydro's TIR, the IC's project must have sufficient reactive power capability over full MW operating range including at the zero MW output level. The Williams Lake Solar farm as submitted does not meet the reactive capability requirement which will need to be addressed.
5. BC Hydro will provide line protection for new line between BC Hydro SCK substation and IC's Williams Lake Solar (P106) substation (BC Hydro end only). As part of the line protection for the new line, telecommunication facilities will be required between the two terminals to accommodate the new protection schemes. In addition, protection upgrades are required at SCK substation for the new 230 kV bus and the new shunt reactor 2RX1. The IC shall provide required relays, telecom facility and associated equipment at its facilities to accommodate the new protection schemes.

## Appendix A

### Plant Single Line Diagram Used for Power Flow Study

Figure A-1 shows Williams Lake Solar Project single line diagram used for power flow study.




Figure A-1: Williams Lake Solar Project Single Line Diagram for Power Flow Study.

As seen in the diagram, Williams Lake Solar Project has two main power transformers dividing the plant into two parts.

- Part 1 has five (5) feeders connecting 25 solar inverters to the collector station.
- Part 2 has five (5) feeders connecting 25 solar inverters to the collector station.

## Appendix B

### One-Line Sketch for Addition of a 230 kV Line Position at SCK Substation

Figure B-1 shows the Stations Planning One-Line Sketch of the existing SCK substation with the connection of IC's project.




Figure B-1: Stations Planning One-Line Sketch of the existing SCK substation with the connection of IC's project.