

6911 Southpoint Drive (B03)
Burnaby, BC
V3N 4X8

July 30, 2024

[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]

[REDACTED]

[REDACTED]

RE: CEAP IR 29 - 200MW Generation Station-Endako Project - Interconnection Feasibility Study Report

Enclosed is the Interconnection Feasibility study report for the proposed 200MW Generation Station-Endako Project submitted under Attachment M-2: Transmission Service and Interconnection Service Procedures for Competitive Electricity Acquisition Process (CEAP) of the Open Access Transmission Tariff (OATT). This letter provides a non-binding good faith estimate of the cost and time to construct the facilities required to interconnect your project to BC Hydro's Transmission System, being the Network Upgrades, based on the findings of the Interconnection Feasibility study.

Open Access Transmission Tariff

The OATT defines Network Upgrades as additions, modifications, and upgrades to BC Hydro's Transmission System required at or beyond the Point of Interconnection to accommodate the interconnection of the Generating Facility to the BC Hydro's Transmission System. Pursuant to the OATT, BC Hydro will design, procure, construct, install, and own the Network Upgrades. While BC Hydro will pay the costs for the Network Upgrades, the Interconnection Customer provides security for such costs.

Cost Estimate

Based on the Interconnection Feasibility study, the non-binding good faith estimated cost (typical accuracy range of +150%/-50%) for Network Upgrades required to interconnect your project is \$12.7 M.

Major Scope of Work Identified:

- Supply and install 230 kV line position with the associated substation equipment at BC Hydro's Glenan (GLN) substation
- Supply and install 230 kV circuit breaker and associated disconnects in the existing 230 kV bus structure at GLN
- Supply and install protection relays and other required protection / telecom equipment

Exclusions:

- GST
- Right-of-Way or Property costs
- Permits

Key Assumptions:

- Construction will be done by contractor
- 2 years of construction
- Early Engineering and Procurement
- No expansion of station or control building required to accommodate new equipment
- No piles or ground improvements will be required
- No contaminated soil will be encountered during construction

Key Risks:

- No defined supply chain strategy, construction costs may increase depending on delivery method
- Cost of construction may increase based on geotechnical condition of the actual project site
- Project schedule may be longer than expected, leading to increased costs
- Costs materials and major equipment be affected by market conditions and escalation
- Additional cost and / or schedule risk if expansion of the site if necessary to accommodate the new facilities (mentioned above) in 230 kV Switchyard at GLN

Please note that the Revenue Metering requirements and associated costs required to interconnect your project have not been determined at this stage and, therefore, not included in the above estimate. Revenue Metering costs that are attributable to the Interconnection Customer are to be paid in cash. For more details on Revenue Metering requirements and responsibilities, please refer to:

<https://www.bchydro.com/content/dam/BCHydro/customer-portal/documents/distribution/standards/ds-rmr-complex-revenue-metering.pdf>.

Schedule

Based on the Interconnection Feasibility study, the non-binding good faith estimated in-service date for your project's Network Upgrades is Quarter 4 2030 (calendar year). To achieve this timeline, we may need to expedite certain activities, including engineering design and procurement of long-lead equipment.

Timely actions required from you to minimize risks to the schedule:

- Submission of additional technical data required for the System Impact Study and Facilities Study
- Submission of any required information or document such as demonstration of Site Control
- Execution of Combined Study Agreement and Standard Generator Interconnection Agreement
- Financial commitments and securities


Please note that changes to your interconnection request, delays in data submission, or financial commitments may also impact the target in-service date.

Next Steps

In September 2024, we will issue a final invoice for the Feasibility Study costs. This invoice will reflect the total amount due, taking into account the \$15,000 Feasibility Study deposit you have already paid and any remaining amount on the non-refundable \$15,000 Interconnection request deposit that we did not spend in reviewing and validating your interconnection request.

If you have any questions, please contact the BC Hydro CEAP Team at ceap2024@bchydro.com.

Sincerely,



Senior Manager, Transmission Interconnections

BC Hydro

Encl.: CEAP2024_IR_29_200MW Generation Station-Endako_FeS_Report_final.pdf




Endako Biomass Project

Interconnection Feasibility Study

BC Hydro EGBC Permit to Practice No: 1002449

2024 CEAP IR # 29

Prepared for:





Report Metadata

Header: Endako Biomass Project
Subheader: Interconnection Feasibility Study
Title: Endako Biomass Project
Subtitle: 2024 CEAP IR # 29
Report Number: 900-APR-00009
Revision: 0
Confidentiality: Public
Date: 2024 Jul 30
Volume: 1 of 1

Prepared for: [Redacted]
[Redacted]
[Redacted]
[Redacted]
[Redacted]
[Redacted]
[Redacted]
[Redacted]

Related Facilities: Glenannan substation (GLN)
Additional Metadata: Transmission Planning 2024-50
Filing Subcode 1350



Revisions

Revision	Date	Description
0	2024 Jul	Initial release



Disclaimer of Warranty, Limitation of Liability

This report was prepared solely for internal purposes. All parties other than BC Hydro are third parties.

BC Hydro does not represent, guarantee or warrant to any third party, either expressly or by implication:

any information, product or process disclosed, described or recommended in this report.

BC Hydro does not accept any liability of any kind arising in any way out of the use by a third party of any information, product or process disclosed, described or recommended in this report, nor does BC Hydro accept any liability arising out of reliance by a third party upon any information, statements or recommendations contained in this report. Should third parties use or rely on any information, product or process disclosed, described or recommended in this report, they do so entirely at their own risk.

This report was prepared by the British Columbia Hydro And Power Authority ("BCH") or, as the case may be, on behalf of BCH by persons or entities including, without limitation, persons or entities who are or were employees, agents, consultants, contractors, subcontractors, professional advisers or representatives of, or to, BCH (individually and collectively, "BCH Personnel").

This report is to be read in the context of the methodology, procedures and techniques used, BCH's or BCH's Personnel's assumptions, and the circumstances and constraints under which BCH's mandate to prepare this report was performed. This report is written solely for the purpose expressly stated in this report, and for the sole and exclusive benefit of the person or entity who directly engaged BCH to prepare this report. Accordingly, this report is suitable only for such purpose, and is subject to any changes arising after the date of this report. This report is meant to be read as a whole, and accordingly no section or part of it should be read or relied upon out of context.

Unless otherwise expressly agreed by BCH:


- (a) any assumption, data or information (whether embodied in tangible or electronic form) supplied by, or gathered from, any source (including, without limitation, any consultant, contractor or subcontractor, testing laboratory and equipment suppliers, etc.) upon which BCH's opinion or conclusion as set out in this report is based (individually and collectively, "Information") has not been verified by BCH or BCH's Personnel; BCH makes no representation as to its accuracy or completeness and disclaims all liability with respect to the Information;
- (b) except as expressly set out in this report, all terms, conditions, warranties, representations and statements (whether express, implied, written, oral, collateral, statutory or otherwise) are excluded to the maximum extent permitted by law and, to the extent they cannot be excluded, BCH disclaims all liability in relation to them to the maximum extent permitted by law;
- (c) BCH does not represent or warrant the accuracy, completeness, merchantability, fitness for purpose or usefulness of this report, or any information contained in this report, for use or consideration by any person or entity. In addition, BCH does not accept any liability arising out of reliance by a person or entity on this report, or any information contained in this report, or for any errors or omissions in this report. Any use, reliance or publication by any person or entity of this report or any part of it is at their own risk; and
- (d) In no event will BCH or BCH's Personnel be liable to any recipient of this report for any damage, loss, cost, expense, injury or other liability that arises out of or in connection with this report including, without limitation, any indirect, special, incidental, punitive or consequential loss, liability or damage of any kind.

Copyright Notice

Copyright and all other intellectual property rights in, and to, this report are the property of, and are expressly reserved to, BCH. Without the prior written approval of BCH, no part of this report may be reproduced, used or distributed in any manner or form whatsoever.



Executive Summary

 the interconnection customer (IC), requests to interconnect its Endako Biomass Project (2024 CEAP IR # 29) to the BC Hydro (BCH) system. Endako Biomass Project Endako Biomass Project has six (6) synchronous generators with total installed capacity of 200 MW. The proposed Point of Interconnection (POI) is on the 230 kV bus of existing BC Hydro's Glenannan substation (GLN). The IC's project will connect to the POI via a 8 km customer built 230 kV interconnection line (2LP29). The IC's proposed commercial operation date (COD) is October 30, 2030.

To interconnect the Endako Biomass Project and its facilities to the BCH Transmission System at the proposed POI, this Feasibility Study has identified the following conclusions and requirements:

1. A new 230 kV line position at GLN is required to interconnect the IC's generating project to the BC Hydro system.
2. The connection of Endako Biomass Project does not cause any performance violation (i.e. thermal overload, voltage performance violation or voltage stability concern) under system normal and single contingency conditions.
3. An Anti-islanding Transfer Trip Scheme to Endako Biomass Substation (P29) is required to isolate the biomass plant when it is islanded with local loads during various operation conditions or under system contingencies (such as loss of both GLN T1 and GLN T2, or loss of both 5L61 and 5L62, or GLN 230 kV breaker internal faults resulting in Endako Biomass plant islanded with 2L353...). In addition, the IC is required to install anti-islanding protection within their facility to disconnect the IC's biomass plant from the grid when an inadvertent island with the local load forms.
4. If 5L61 is forced out of service, North Coast system including Endako Biomass Plant will form an island. It is required that Endako Biomass generation participates in the existing North Coast Generation Shedding Application/Scheme.
5. The new line 2LP29 (from GLN to P29) will become IC's Bulk Electric System (BES) and IC will be responsible for compliance with applicable MRS requirements.



6. BC Hydro will provide line protections for 2LP29 (BC Hydro end only). As part of the new line protection, telecommunication facilities will be required between GLN and Endako Biomass plant (P29). The IC shall provide required relays, telecom facility and associated equipment at its facilities to accommodate the new protection schemes.

The above conclusions are made based on the IC's input data and study assumptions listed in Section 4, which represent the best available information on May 22, 2024.

A non-binding good faith estimated cost and time to construct the Network Upgrades required to interconnect the proposed project will be provided in a separate letter to the IC.



Contents

Executive Summary	vii
1 Introduction	1
2 Purpose and Scopes of Study	3
3 Standard and Criteria	4
4 Assumptions and Conditions	5
5 System Studies and Results	6
5.1 Power Flow Study Results	6
5.1.1 Branch Loading Analysis	6
5.1.2 Steady-State Voltage Analysis	7
5.1.3 Islanding Requirements	7
5.2 Fault Analysis	8
5.3 Stations Requirements	8
5.4 Protection & Control Requirements	8
5.5 Telecommunications Requirements	9
6 Cost Estimate and Schedule	11
7 Conclusions	12

Appendices

Appendix A	Plant Single Line Diagram Used for Power Flow Study
Appendix B	One-Line Sketch at GLN



Acronyms

The following are acronyms used in this report.

BCH	BC Hydro
CEAP	Competitive Electricity Acquisition Process
COD	Commercial Operation Date
DTT	Direct Transfer Trip
ERIS	Energy Resource Interconnection Service
FeS	Feasibility Study
IBR	Inverter-Based Resources
IC	Interconnection Customer
LAPS	Local Area Protection Schemes
MPO	Maximum Power Output
NERC	North American Electric Reliability Corporation
NRIS	Network Resource Interconnection Service
OATT	Open Access Transmission Tariff
POI	Point of Interconnection
RAS	Remedial Action Scheme
TIR	BC Hydro “60 kV to 500 kV Technical Interconnection Requirements for Power Generators”
WECC	Western Electricity Coordinating Council
WTG	Wind Turbine Generator
EDM	Edmonds Office
FVO	Fraser Valley Office
WSN	Williston Substation
GLN	Glenannan Substation
SIO	South Interior Office
P29	Endako Biomass plant (unofficial site code)
2LP29	230kV transmission line from GLN to P29



1 Introduction

Table 1-1 below summarizes the project reviewed in this Feasibility Study.

Table 1-1 Summary of Project Information

Project Name	Endako Biomass Project	
Name of Interconnection Customer (IC)	[REDACTED]	
Point of Interconnection (POI)	Glenannan substation 230kV bus	
IC's Proposed COD	30 October 2030	
Type of Interconnection Service	NRIS <input checked="" type="checkbox"/>	ERIS <input type="checkbox"/>
Maximum Power Injection (MW)	195 MW (Summer)	195 MW (Winter)
Number of Generator Units	6	
Plant Fuel	Biomass	

[REDACTED] the interconnection customer (IC), requests to interconnect its Endako Biomass Project (2024 CEAP IR # 29) to the BC Hydro system. Endako Biomass Project has six (6) synchronous generators with total installed capacity of 200 MW. The IC's proposed Point of Interconnection (POI) is at the 230 kV bus of existing BC Hydro's Glenannan substation (GLN). The IC's project will connect to the POI via a 8 km customer built 230 kV interconnection line (2LP29). The IC's proposed commercial operation date (COD) is October 30, 2030.

Figure 1-1 shows the Glenannan transmission system diagram. BC Hydro's North Coast (NC) service area is supplied through a radial 500 kV transmission circuit that comprises three transmission lines: 5L61 between the Williston substation (WSN) and the Glenannan substation (GLN), 5L62 between GLN and the Telkwa substation (TKW), and 5L63 between TKW and the Skeena substation (SKA). GLN is a major substation in North Coast with two existing 500/230 kV transformers (WSN T1 & T2) and several step-down transformers to serve 230kV/138kV/66kV loads.




Figure 1-1: Glenannan Regional Transmission System Diagram with the Proposed Endako Biomass Project Interconnection

In the Glenannan region, there are two generation plants.

- Fort St. James Green Energy Generating Station (FGE) has a total capacity of 40 MW and is connected to TAC via the line 60L344.
- Fraser Lake Biomass Generating Station (FLB) has a total capacity of 7.2 MW and is connected to GLN Substation via 60L329.



2 Purpose and Scopes of Study

This Feasibility Study is a preliminary evaluation of the system impact of interconnecting the proposed project to the BC Hydro system based on power flow and short circuit analysis in accordance with BCH's Open Access Transmission Tariff (OATT). A non-binding good faith estimated cost of required Network Upgrades and estimated time to construct will be provided.

Per OATT, the feasibility study is performed individually for each of the participating projects in the CEAP and focuses specifically on the BC Hydro regional transmission system where the proposed generating project is proposed to be constructed. An assessment of the incremental effect on the 500kV bulk transmission system is beyond this study scope.

This is a "limited scope" study which is restricted to power flow studies of P0, P1 and P2 planning events as defined in TPL-001-4 and short circuit analysis. The study does not address other technical aspects such as transient stability and switching transients and impact of multiple contingencies. These subjects would be addressed in subsequent System Impact Study if the project is a Successful Participant of the CEAP.

In case impact to the adjacent external systems to BC Hydro is observed, such impact would be addressed in subsequent detailed and coordinated studies with the relevant adjacent entities if the proposed interconnection proceeds further.



3 Standard and Criteria

The Feasibility Study is performed in compliance with the North American Electric Reliability Corporation (NERC) and Western Electricity Coordinating Council (WECC) reliability standards, and the BCH interconnection requirements in the TIR, and upon the ratings of the existing BCH transmission facilities described in Operating Orders, specifically:

- NERC standards: TPL-001-4 and FAC-002-3 relevant to the scope of this Feasibility Study.
- WECC criteria TPL-001-WECC-CRT-4 Transmission System Planning Performance, July 1, 2023.
- BC Hydro's 60 kV to 500 kV Technical Interconnection Requirements for Power Generators.
- BC Hydro Operating Order 5T-10, Ratings for All Transmission Circuits 60 kV or Higher, April 16, 2024.
- BC Hydro Operating Order 5T-14, Ratings for All Transmission and Distribution Transformer, November 8, 2022.
- BC Hydro System Operating Order 7T-22 System Voltage Control, September 19, 2023.



4 Assumptions and Conditions

This Feasibility Study is performed based on the IC's submitted data and information available to BC Hydro on May 22, 2024 for the study purpose.. Appendix A shows the plant single line diagram for the IC's project used in the study model. Certain assumptions were, as set out below, made to the extent required.

The power flow study cases used in this Feasibility Study are established based upon the BC Hydro's base resource plan and load forecasts available at the time of performing the study, which includes existing and future generations, transmission facilities, and loads in addition to the subject interconnection project in this study. Applicable seasonal conditions and the appropriate study years for the study planning horizon are also incorporated.

Additional assumptions are listed as follows.

- 1) The regional generation are dispatched to the patterns that stress the transmission system in the study area. In these patterns, the regional generations are typically set to their Maximum Power Outputs (MPO) unless otherwise specified.



5 System Studies and Results

Based upon the IC's submitted information and the area system conditions, a new 230 kV line position at GLN is required to interconnect the IC's generating project to the BC Hydro system.

The IC's project will connect to the POI via a 8 km 230 kV interconnection line, 2LP29. The new line 2LP29 will become an IC's Bulk Electric System (BES) element and the IC will be responsible for the compliance with applicable MRS requirements.

5.1 Power Flow Study Results

Power flow studies were performed to evaluate whether the IC's generating project would cause any unacceptable system performance (e.g. equipment overloads, steady-state voltage violation and voltage instability) and to determine the reinforcement requirement based on steady state performance analysis.

The study focuses on the 2031 light summer (31LS) system load condition which is typically a stressed condition for a generation interconnection project, taking into considerations of factors such as load conditions, seasons, and generation patterns. The 2031 heavy summer (31HS) and 2031 heavy winter (31HW) cases are also checked at a high level to capture any possibility of performance violations under high load conditions.

5.1.1 Branch Loading Analysis

Table 5-1 shows a summary of branch loading analysis under system normal and single contingencies (P1, P2) for various load conditions.

For all the studied load conditions (31LS, 31HS, 31HW), there is no other branch or transformer overload identified under system normal condition and single contingencies.

Table 5-1: Summary of Branch Loading Analysis Results

Case	IC's Plant Output	Contingency		Branch Loading	
				GLN T1	GLN T2
		Cat.	Description	500/230kV transformer	500/230kV transformer
Winter Rating				714 MVA	714 MVA
31HW	Max	P0	System Normal	8%	8%

	Max	P1	GLN T1	N/A	16%
	Max	P1	GLN T2	16%	N/A
Summer Rating				600 MVA	600 MVA
31HS	Max	P0	System Normal	12%	12%
	Max	P1	GLN T1	N/A	24%
	Max	P1	GLN T2	24%	N/A
31LS	Max	P0	System Normal	13%	13%
	Max	P1	GLN T1	N/A	26%
	Max	P1	GLN T2	26%	N/A

5.1.2 Steady-State Voltage Analysis

With the connection of the IC's project, the voltage performance under system normal condition and single contingencies is acceptable for all the three load conditions (31LS, 31HS, 31HW). Table 5-2 shows a summary of steady-state voltage performance under various system conditions and contingencies.

The study also finds that Endako Biomass Project could improve the load bus voltage at GLN under heavy load conditions.

Table 5-2: Summary of Steady-State Voltage Study Results

Case	IC's Plant Output	Contingency		Bus Voltage (PU)		
		Cat.	Description	GLN 230kV	P29 230kV	TAC 230kV
31HW	Max	P0	System normal	1.03	1.03	1.02
31HS	Max	P0	System normal	1.03	1.024	1.021
	0 MW	P0	System normal	1.035	1.035	1.024
31LS	Max	P0	System normal	1.04	1.04	1.03
	0 MW	P0	System normal	1.04	1.04	1.03

5.1.3 Islanding Requirements

During various operation conditions or under system contingencies (such as loss of both GLN T1 and GLN T2, or loss of both 5L61 and 5L62, or GLN 230 kV breaker internal faults resulting in Endako Biomass plant islanded with 2L353...), the IC's project will be inadvertently islanded with the existing generators and BC Hydro loads, which is not allowed. An Anti-islanding Transfer Trip Scheme to P29 is required to isolate the biomass plant. In addition, the IC is required to install anti-islanding protection within its facility to disconnect the IC's biomass plant from the grid when an inadvertent island with the local load forms.



If 5L61 is forced out of service, North Coast system including Endako Biomass Plant will form an island. It is required that Endako Biomass generation participates in the existing North Coast Generation Shedding Application/Scheme.

5.2 Fault Analysis

The short circuit analysis in the FS is based upon the latest BC Hydro system model, which includes the generating facility information and associated impedance data provided by the IC. A more detailed study will be performed at the system impact study stage if needed.

5.3 Stations Requirements

A new 230 kV line position at GLN is required to interconnect the IC's generating project to the BC Hydro system. The IC's project will connect to the POI via a 8 km customer built 230 kV interconnection line, 2LP29.

Following is the scope of station work in GLN 230kV switchyard:

- Add a new 230 kV circuit breaker (2CB8) and associated disconnect in the existing 230 kV bus structure.
- Add disconnect, associated with existing 2CB7 circuit breaker.
- Expansion of the site if necessary to accommodate the new facilities (mentioned above) in 230 kV switchyard. It is assumed that property is available for this site expansion if required.
- Add one 230 kV line position with the associated substation equipment.
- Terminate Endako biomass ([REDACTED] [REDACTED] [REDACTED]) 2LP29 230 kV transmission line.
- Other associated station work.

Refer to Appendix B - One-Line Sketch at GLN for details.

5.4 Protection & Control Requirements

BC Hydro will provide line protections for 2LP29 230 kV transmission line (BC Hydro end only) that will integrate Endako Biomass Plant to BC Hydro system at GLN. As part of the new line protection, telecommunication facilities will be required between GLN and Endako Biomass Plant (P29).

The IC is to provide the following for the interconnection of Endako biomass plant.



- Entrance protection that complies with the latest version of the “60 kV to 500 kV BC Hydro Technical Interconnection Requirements for Power Generators.”
- Provide two SEL-411L-1 relays (firmware and options specified by BC Hydro) at the entrance of P29 to provide protection coverage for 2LP29 line. BC Hydro P&C Planning will provide core protection settings for these relays to protect transmission line 2LP29 between GLN and P29 during a transmission line fault. Non-core protection such as local breaker failure, auto-reclosing, backup protection for station elements will not be provided by BC Hydro P&C Planning.
- The IC is responsible for NERC PRC-related tasks, settings to compliance standards within their facilities.
- The IC is responsible for providing a communications link for remote interrogation of the PPIS equipment by BCH servers.
- Provide islanding protection as stated in Section 5.1.

The RAS requirements stated in Section 5.1 are mainly to address the islanding concerns, which are preliminary. These RAS requirements may utilize the communication channels required for protection purposes included in the cost estimate. If the proposed project proceeds through the CEAP process, subsequent System Impact Studies may identify additional RAS requirements for this interconnection. These RAS functional requirements will include initiating events, control actions, and latency times. Depending on these supplementary requirements, additional telecommunication facilities may be needed to facilitate signal transmission between the BC Hydro substations and customer facilities.

5.5 Telecommunications Requirements

BC Hydro performed a high-level feasibility assessment of a telecom solution to meet the following requirements.

Teleprotection Requirements for Telecom

- WECC Level 3 64 kbps synchronous circuits between GLN and P29 for “P29-GLN 2LP29 PY DIGITAL TELEPROT” and “P29-GLN 2LP29 SY DIGITAL TELEPROT”. Physical interface shall be C37.94 optical over multimode fibre using ST connectors.

Telecontrol Requirements for Telecom

- P29 SCADA circuit to FVO and SIO.



Certain assumptions were made for determining a potential telecom solution. Details of the telecom solution (e.g. assumptions made, alternatives investigated and work required for BCH and the IC) would be provided at the next study stage.



6 Cost Estimate and Schedule

The non-binding good faith estimated cost and time to construct the Network Upgrades required to interconnect the proposed project will be provided in a separate letter to the IC.



7 Conclusions


To interconnect the Endako Biomass Project and its facilities to the BCH Transmission System at the POI, this Feasibility Study has identified the following conclusions and requirements:

1. A new 230 kV line position at GLN is required to interconnect the IC's generating project to the BC Hydro system.
2. The connection of Endako Biomass Project does not cause any performance violation (i.e. thermal overload, voltage performance violation or voltage stability concern) under system normal and single contingency conditions.
3. An Anti-islanding Transfer Trip Scheme to Endako Biomass Substation (P29) is required to isolate the biomass plant when it is islanded with local loads during various operation conditions or under system contingencies (such as loss of both GLN T1 and GLN T2, or loss of both 5L61 and 5L62, or GLN 230 kV breaker internal faults resulting in Endako Biomass plant islanded with 2L353...). In addition, the IC is required to install anti-islanding protection within their facility to disconnect the IC's biomass plant from the grid when an inadvertent island with the local load forms.
4. If 5L61 is forced out of service, North Coast system including Endako Biomass Plant will form an island. It is required that Endako Biomass generation participates in the existing North Coast Generation Shedding Application/Scheme.
5. The new line 2LP29 (from GLN to P29) will become IC's BES and IC will be responsible for compliance with applicable MRS requirements.
6. BC Hydro will provide line protections for 2LP29 (BC Hydro end only). As part of the new line protection, telecommunication facilities will be required between GLN and Endako Biomass plant (P29). The IC shall provide required relays, telecom facility and associated equipment at its facilities to accommodate the new protection schemes.

Appendix A

Plant Single Line Diagram Used for Power Flow Study

Figure A-1: Endako Biomass Project Single Line Diagram for Power Flow Study.



As seen in the diagram, Endako Biomass Project has six (6) generator step-up transformers connecting six synchronous generators.

Appendix B

One-Line Sketch for GLN

Figure B-1 shows the Stations Planning One-Line Sketch for GLN.




Figure B-1: Stations Planning One-Line Sketch for GLN.