

6911 Southpoint Drive (B03)
Burnaby, BC
V3N 4X8

July 30, 2024

[REDACTED]

RE: CEAP IR 65 - Mount Thynne Wind Project - Interconnection Feasibility Study Report

Enclosed is the Interconnection Feasibility study report for the proposed Mount Thynne Wind Project submitted under Attachment M-2: Transmission Service and Interconnection Service Procedures for Competitive Electricity Acquisition Process (CEAP) of the Open Access Transmission Tariff (OATT). This letter provides a non-binding good faith estimate of the cost and time to construct the facilities required to interconnect your project to BC Hydro's Transmission System, being the Network Upgrades, based on the findings of the Interconnection Feasibility study.

Open Access Transmission Tariff

The OATT defines Network Upgrades as additions, modifications, and upgrades to BC Hydro's Transmission System required at or beyond the Point of Interconnection to accommodate the interconnection of the Generating Facility to the BC Hydro's Transmission System. Pursuant to the OATT, BC Hydro will design, procure, construct, install, and own the Network Upgrades. While BC Hydro will pay the costs for the Network Upgrades, the Interconnection Customer provides security for such costs.

Cost Estimate

Based on the Interconnection Feasibility study, the non-binding good faith estimated cost (typical accuracy range of +150%/-50%) for Network Upgrades required to interconnect your project is \$125.2M.

Major Scope of Work Identified:

- Acquire adequate property for a new substation close to the existing transmission line 1L251
- Construct a new outdoor 138kV, 3-circuit breaker ring bus switching substation
- Replacement and addition of structures on 1L251 required to accommodate addition of new fibre optic cable
- Supply and install 48-strand fibre optic cable on 1L251 structures ~51km
- Supply and install microwave tower, waveguides, antennas, and other required telecommunications equipment
- Install protection relays and other required protection equipment

Exclusions:

- GST
- Right-of-way
- Permits

Key Assumptions:

- Construction by contractor
- 3 years of construction
- No expansion of existing stations or control buildings to accommodate new equipment
- Early Engineering and Procurement
- No piles will be required for construction
- No contaminated soil will be encountered during construction
- Series capacitor station on 1L251 installed as part of higher queued project
- A Certificate of Public Convenience and Necessity (CPCN) requirement will not impact the schedule

Key Risks:

- Additional right of way or acquisition of more property may be required
- Existing microwave towers may need to be upgraded at various sites to accommodate new equipment leading to increased costs
- Transmission routing may be different than assumed, including number of disconnect switches and structure types may change
- No defined supply chain strategy, construction costs may increase depending on delivery method
- Cost of construction may increase based on geotechnical condition of the actual project site
- Project schedule may be longer than expected, leading to increase costs
- Costs may be affected by market conditions and escalation
- A CPCN requirement may delay the project schedule and increase costs

Please note that the Revenue Metering requirements and associated costs required to interconnect your project have not been determined at this stage and, therefore, not included in the above estimate. Revenue Metering costs that are attributable to the Interconnection Customer are to be paid in cash. For more details on Revenue Metering requirements and responsibilities, please refer to:

<https://www.bchydro.com/content/dam/BCHydro/customer-portal/documents/distribution/standards/ds-rmr-complex-revenue-metering.pdf>.

Schedule

Based on the Interconnection Feasibility study, the non-binding good faith estimated in-service date for your project's Network Upgrades is Quarter 3 2031 (calendar year). To achieve this timeline, we may need to expedite certain activities, including engineering design and procurement of long-lead equipment.

Timely actions required from you to minimize risks to the schedule:

- Submission of additional technical data required for the System Impact Study and Facilities Study
- Submission of any required information or document such as demonstration of Site Control
- Execution of Combined Study Agreement and Standard Generator Interconnection Agreement
- Financial commitments and securities


Please note that changes to your interconnection request, delays in data submission, or financial commitments may also impact the target in-service date.

Next Steps

In September 2024, we will issue a final invoice for the Feasibility Study costs. This invoice will reflect the total amount due, taking into account the \$15,000 Feasibility Study deposit you have already paid and any remaining amount on the non-refundable \$15,000 Interconnection request deposit that we did not spend in reviewing and validating your interconnection request.

If you have any questions, please contact the BC Hydro CEAP Team at ceap2024@bchydro.com.

Sincerely,



Senior Manager, Transmission Interconnections

BC Hydro

Encl.: CEAP2024_IR_65_Mount Thynne Wind_FeS_Report_final.pdf




Mount Thynne Wind Project

Interconnection Feasibility Study

BC Hydro EGBC Permit to Practice No: 1002449

2024 CEAP IR # 65

Prepared for:





Report Metadata

Header: Mount Thynne Wind Project
Subheader: Interconnection Feasibility Study
Title: Mount Thynne Wind Project
Subtitle: 2024 CEAP IR # 65
Report Number: 300-APR-00016
Revision: 0
Confidentiality: Public
Date: 2024 Jul 30
Volume: 1 of 1

Prepared for: [Redacted]
[Redacted]
[Redacted]
[Redacted]
[Redacted]
[Redacted]
[Redacted]

Related Facilities: 1L251
Additional Metadata: Transmission Planning 2024-076
Filing Subcode 1350



Revisions

Revision	Date	Description
0	2024 Jul	Initial release



Disclaimer of Warranty, Limitation of Liability

This report was prepared solely for internal purposes. All parties other than BC Hydro are third parties.

BC Hydro does not represent, guarantee or warrant to any third party, either expressly or by implication:

any information, product or process disclosed, described or recommended in this report.

BC Hydro does not accept any liability of any kind arising in any way out of the use by a third party of any information, product or process disclosed, described or recommended in this report, nor does BC Hydro accept any liability arising out of reliance by a third party upon any information, statements or recommendations contained in this report. Should third parties use or rely on any information, product or process disclosed, described or recommended in this report, they do so entirely at their own risk.

This report was prepared by the British Columbia Hydro And Power Authority ("BCH") or, as the case may be, on behalf of BCH by persons or entities including, without limitation, persons or entities who are or were employees, agents, consultants, contractors, subcontractors, professional advisers or representatives of, or to, BCH (individually and collectively, "BCH Personnel").

This report is to be read in the context of the methodology, procedures and techniques used, BCH's or BCH's Personnel's assumptions, and the circumstances and constraints under which BCH's mandate to prepare this report was performed. This report is written solely for the purpose expressly stated in this report, and for the sole and exclusive benefit of the person or entity who directly engaged BCH to prepare this report. Accordingly, this report is suitable only for such purpose, and is subject to any changes arising after the date of this report. This report is meant to be read as a whole, and accordingly no section or part of it should be read or relied upon out of context.

Unless otherwise expressly agreed by BCH:


- (a) any assumption, data or information (whether embodied in tangible or electronic form) supplied by, or gathered from, any source (including, without limitation, any consultant, contractor or subcontractor, testing laboratory and equipment suppliers, etc.) upon which BCH's opinion or conclusion as set out in this report is based (individually and collectively, "Information") has not been verified by BCH or BCH's Personnel; BCH makes no representation as to its accuracy or completeness and disclaims all liability with respect to the Information;
- (b) except as expressly set out in this report, all terms, conditions, warranties, representations and statements (whether express, implied, written, oral, collateral, statutory or otherwise) are excluded to the maximum extent permitted by law and, to the extent they cannot be excluded, BCH disclaims all liability in relation to them to the maximum extent permitted by law;
- (c) BCH does not represent or warrant the accuracy, completeness, merchantability, fitness for purpose or usefulness of this report, or any information contained in this report, for use or consideration by any person or entity. In addition, BCH does not accept any liability arising out of reliance by a person or entity on this report, or any information contained in this report, or for any errors or omissions in this report. Any use, reliance or publication by any person or entity of this report or any part of it is at their own risk; and
- (d) In no event will BCH or BCH's Personnel be liable to any recipient of this report for any damage, loss, cost, expense, injury or other liability that arises out of or in connection with this report including, without limitation, any indirect, special, incidental, punitive or consequential loss, liability or damage of any kind.

Copyright Notice

Copyright and all other intellectual property rights in, and to, this report are the property of, and are expressly reserved to, BCH. Without the prior written approval of BCH, no part of this report may be reproduced, used or distributed in any manner or form whatsoever.



Executive Summary

 the Interconnection Customer (IC), requests to interconnect its Mount Thynne Wind Project (2024 CEAP IR # 65) to the BC Hydro (BCH) system. This project includes 26 x 6.35 MVA (total 165.1 MVA / 153.4 MW) wind turbines. The maximum power injection into the BCH transmission system is 130 MW. The IC proposed Point of Interconnection (POI) is on the radially connected 138 kV transmission line 1L251, about 11.6 km from Similco Substation (SCO). The IC owned station is connected to the system through an IC owned 26.9 km 138 kV tie line to the POI. The proposed project's Commercial Operation Date (COD) is November 1, 2028.

To interconnect the Mount Thynne Wind Project and its facilities to the BCH Transmission System at the proposed POI, this Feasibility Study (FeS) has identified the following conclusions and requirements:

1. A new 138 kV switching station (referred to as "P65T") on 1L251 is required at the proposed POI for interconnecting the IC's generating project to the BCH system. With the new switching station P65T, 1L251 will be segregated into two segments, and three new lines to be terminated in are temporarily referred to as: 1L251_A (NIC-P65T), 1L251_B (P65T-CUM) and 1L251_C (P65T-P65P).
2. The connection of Mount Thynne Wind Project does not cause any performance violation (i.e. thermal overload, voltage performance violation or voltage stability concern) under system normal and single contingency conditions.
3. In addition to the project's entrance protection and 1L251_C line protection, the IC is required to install anti-islanding protection within its facility to detect and disconnect itself from the BC Hydro transmission system if an inadvertent island with the local loads forms. In addition, a direct transfer trip (DTT) from NIC to the new switching station P65T is required to disconnect the project for protective and unintentional tripping of 1L251_A at NIC or P65T.



4. It is required to furnish and install 48-strand fibre optic cable on 1L251 from 1L251 series capacitor project to P65T for telecommunication. The length is approximately 38 km. Structure replacement and mid span structures may be required due to fibre addition.
5. The new line 1L251_A will become part of BC Hydro BES and need to be compliant with applicable NERC MRS requirements. The IC's line 1L251_C may be a BES element as well. The new line 1L251_B (P65T-CUM) will remain as a non-BES line.
6. BCH will provide line protections for 1L251_A, 1L251_B and 1L251_C (BCH end only) protections. As part of the line protection replacements for each of the three lines, telecommunication facilities will be required to accommodate the new protection schemes.

The above conclusions are made based on the IC's input data and study assumptions listed in Section 4, which represent the best available information on May 22, 2024.

A non-binding good faith estimated cost and time to construct the Network Upgrades required to interconnect the proposed project will be provided in a separate letter to the IC.



Contents

Executive Summary	vii
1 Introduction	1
2 Purpose and Scopes of Study	3
3 Standard and Criteria	4
4 Assumptions and Conditions	5
5 System Studies and Results	6
5.1 Power Flow Study Results	6
5.1.1 Branch Loading Analysis	6
5.1.2 Steady State Voltage Analysis	8
5.1.3 Reactive Power Capability Evaluation	8
5.1.4 Anti-Islanding Requirements	9
5.2 Fault Analysis	9
5.3 Stations Requirements	9
5.4 Transmission Line Requirements	10
5.5 Protection & Control Requirements	10
5.6 Telecommunications Requirements	11
6 Cost Estimate and Schedule	12
7 Conclusions	13

Appendix

Appendix A
Plant Single Line Diagram Used for Power Flow Study

Appendix B
One-Line Sketch for New Switching Station

Acronyms

The following are acronyms used in this report.

BCH	BC Hydro
BES	Bulk Electric System
CEAP	Competitive Electricity Acquisition Process
COD	Commercial Operation Date
CUM	Copper Mountain Mine Substation
DTT	Direct Transfer Trip
EDM	Edmonds Office
ERIS	Energy Resource Interconnection Service
FeS	Feasibility Study
FVO	Fraser Valley Office
HAM	Hamilton Microwave Repeater
HLD	Highland Substation
IBR	Inverter-Based Resources
IC	Interconnection Customer
KCH	Kwoiek Creek Generating Station
LAPS	Local Area Protection Schemes
MIG	Merritt Green Energy Ltd
MPO	Maximum Power Output
NERC	North American Electric Reliability Corporation
NIC	Nicola Substation
NRIS	Network Resource Interconnection Service
OATT	Open Access Transmission Tariff
POI	Point of Interconnection
QYS	quA-ymn Solar Farm
RAS	Remedial Action Scheme
SCO	Similco Substation
SGIA	Standard Generation Interconnection Agreement
SIC	South Interior Control
SIO	South Interior Office
TIR	BC Hydro “60 kV to 500 kV Technical Interconnection Requirements for Power Generators”
WECC	Western Electricity Coordinating Council

1 Introduction

Table 1-1 below summarizes the project reviewed in this Feasibility Study.

Table 1-1 Summary of Project Information

Project Name	Mount Thynne Wind Project	
Interconnection Customer	[REDACTED]	
Point of Interconnection	On 1L251, about 11.6 km from Similco Substation	
IC Proposed COD	November 01, 2028	
Type of Interconnection Service	NRIS <input checked="" type="checkbox"/>	ERIS <input type="checkbox"/>
Maximum Power Injection (MW)	130 (Summer)	130 (Winter)
Number of Turbines	26 x 6.35 MVA wind turbines	
Plant Fuel	Wind	

[REDACTED] the Interconnection Customer (IC), requests to interconnect its Mount Thynne Wind Project (2024 CEAP IR # 65) to the BC Hydro (BCH) system. This project has twenty-six (26) [REDACTED] type-3 wind turbine generators with total installed capacity of 153.4 MW. The IC proposed maximum power injection into the BCH transmission system is 130 MW. The Point of Interconnection (POI) is on the radially connected 138 kV transmission line 1L251, about 11.6 km from Similco Substation (SCO). The IC owned station is connected to the system through an IC owned 26.9 km 138 kV tie line to the POI. The proposed project's Commercial Operation Date (COD) is November 1, 2028. The details of the project's electrical configuration can be found in Appendix A.

Figure 1-1 shows the local system where the Mount Thynne Wind Project is connected. There are three industrial load facilities currently fed by circuit 1L251. The industrial facilities are Copper Mountain Mine Substation (CUM), Similco Substation (SCO), and Kingsvale Substation (KPS). The two load substations CUM and SCO are owned by the same customer, [REDACTED]

NIC is one of BCH's major transmission substations, and presently has two 500/230 kV transformers, and two 230/138/12 kV transformers.

There are several high-queued load interconnections and their associated network upgrades in the study area. The relevant network upgrades being planned in the study region are included in the Assumptions and Conditions Section.




Figure 1-1: Nicola-Highland region 138/230 kV Transmission System Diagram

2 Purpose and Scopes of Study

This Feasibility Study is a preliminary evaluation of the system impact of interconnecting the proposed project to the BC Hydro system based on power flow and short circuit analysis in accordance with BCH's Open Access Transmission Tariff (OATT). A non-binding good faith estimated cost of required Network Upgrades and estimated time to construct will be provided.

Per OATT, the feasibility study is performed individually for each of the participating projects in the CEAP process and focuses specifically on the BC Hydro regional transmission system where the proposed generating project is proposed to be constructed. An assessment of the incremental effect on the 500kV bulk transmission system is beyond this study scope.

This is a "limited scope" study which is restricted to power flow studies of P0, P1 and P2 planning events as defined in TPL-001-4 and short circuit analysis. The study does not address other technical aspects such as transient stability and switching transients and impact of multiple contingencies. These subjects would be addressed in subsequent System Impact Study if the project is a Successful Participant of the CEAP.

In case impact to the adjacent external systems to BC Hydro is observed, such impact would be addressed in subsequent detailed and coordinated studies with the relevant adjacent entities if the proposed interconnection proceeds further.

3 Standard and Criteria

This FeS is performed in compliance with the North American Electric Reliability Corporation (NERC) and Western Electricity Coordinating Council (WECC) reliability standards, and the BCH interconnection requirements in the TIR, and upon the ratings of the existing BCH transmission facilities described in Operating Orders, specifically:

- NERC standards: TPL-001-4 and FAC-002-3 relevant to the scope of this Feasibility Study.
- WECC criteria TPL-001-WECC-CRT-4 Transmission System Planning Performance, July 1, 2023.
- BC Hydro's 60 kV to 500 kV Technical Interconnection Requirements for Power Generators.
- BC Hydro Operating Order 5T-10, Ratings for All Transmission Circuits 60 kV or Higher, April 16, 2024.
- BC Hydro Operating Order 5T-14, Ratings for All Transmission and Distribution Transformer, November 8, 2022.
- BC Hydro System Operating Order 7T-22 System Voltage Control, September 19, 2023.

4 Assumptions and Conditions

This Feasibility Study is performed based on the IC's submitted data and information available to BC Hydro on May 21, 2024 for the study purpose. Assumptions are made wherever the IC's input is unavailable. Appendix A shows the plant single line diagram for the IC's project used in the study model.

The power flow study cases used in this Feasibility Study are established based upon the BC Hydro's base resource plan and load forecasts available at the time of performing the study, which includes existing and future generations, transmission facilities, and loads in addition to the subject interconnection project in this study. Applicable seasonal conditions and the appropriate study years for the study planning horizon are also incorporated.

Additional assumptions are listed as follows.

- 1) The regional generation are dispatched to the patterns that stress the transmission system in the study area. In these patterns, the regional generations are typically set to their Maximum Power Outputs (MPO) unless otherwise specified.
- 2) For the purpose of performing this study, Nicola Substation Transformation Capacity Reinforcement project (i.e. addition of NIC T7) is assumed completed by the time the IC's generating project enters service.
- 3) 1L243 reconductoring is assumed completed by the time the IC's generating project enters service. 1L243 after reconductoring is assumed to have a conductor rating of 1145 A (summer) and 1388 A (winter).
- 4) 1L251 series capacitor project: Line 1L251 will be series compensated to accommodate an industrial load increase on 1L251.
- 5) In this study, it is considered that 1L251 will be supplied from NIC only, with the FortisBC side open. This means that whenever the NIC end of 1L251 is open, the Mount Thynne Wind Project will need to be off-line.

5 System Studies and Results

Based upon the IC's submitted information and the area system conditions, a new switching station (referred to as "P65T") at the proposed POI on 1L251 is required to interconnect the IC's generating project to the BCH system. There are multiple terminals and multiple sources on the existing line 1L251. The addition of the new switching station would help to maintain reliability and adequate protection performance to serve the existing customers and the new addition.

With the new switching station P65T, 1L251 will be segregated into two segments, and three new lines to be terminated in are temporarily referred to as: 1L251_A (NIC-P65T), 1L251_B (P65T-CUM) and 1L251_C (P65T-P65P). The temporary line designations will be replaced by permanent designations at a later stage of interconnection study.

The existing line 1L251 does not meet BES criteria and is excluded from the Bulk Electric System (BES) list. The new lines 1L251_A will become part of BCH's Bulk Electric System (BES) and need to be compliant with applicable NERC MRS requirements. The IC's line 1L251_C may be a BES element as well. The new line 1L251_B (P65T-CUM) will remain as a non-BES line.

5.1 Power Flow Study Results

Power flow studies were performed to evaluate whether the IC's generating project would cause any unacceptable system performance (e.g. equipment overloads, steady-state voltage violation and voltage instability) and to determine the reinforcement requirement based on steady state performance analysis.

The study focuses on the 2029 light summer (29LS) system load condition which is typically a stressed condition for a generation interconnection project, taking into considerations of factors such as load conditions, seasons and generation patterns. The 2029 heavy summer (29HS) and 2028 heavy winter (28HW) cases are also checked at a high level to capture any possibility of performance violations under high load conditions.

5.1.1 Branch Loading Analysis

Power flow analyses under system normal (N-0 or P0) and contingency conditions (N-1 or P1 & P2.1) were performed to evaluate whether Mount Thynne Wind

Project would cause any adverse impact on the transmission system.

With proposed power injection of 130 MW to 1L251, there is no thermal overload concern due to interconnection of Mount Thynne Wind Project, because the project's power injection will be largely offset and consumed locally.

In Table 5-1, cases 1, 8, and 10 demonstrate the local system performance prior to the project interconnected. There is no overloading concern under the studied light summer, heavy summer and heavy winter load conditions.

With the project in service, the impacts of different outputs of the project on the loadings of NIC 230/138 kV transformers and 1L251_A, as well as 1L251_B under the system normal condition are shown in case 2 to case 4 of Table 5-1. No concerns have been identified.

With Mount Thynne Wind Project in service, applicable N-1 contingency (P1 or P2.1) will not result in any overloading in the local transmission system, see cases 5 - 7 of Table 5-1.

This study concludes that with Mount Thynne Wind Project to the system, there will be no overloading in the transmission system under system normal (N-0 or P0) and N-1 (P1 or P2.1) contingency conditions.

Table 5-1: Summary of Branch Loading Analysis Results

Case	IC's Power Injection at POI (MW)	Contingency		Line/Equipment Loading (Percentage of The Line/Equipment Rating)				
		Cat.	Cases & Description	1L251_A	1L251_B	NIC T5	NIC T6	NIC T7
29 LS	Summer Rating (MVA)			193.4	120	286.8	286.8	300.0
	N/A (Before the project is connected)	P0	1. System normal	36	48	13	13	15
	130		2. System normal	39	48	3	3	4
	65		3. System normal	4	48	7	7	8
	0		4. System normal	36	48	13	13	15
	130	P1	5. 1L251_B tripped	69	N/A	6	6	7
			6. 1L251 Series Capacitor bypassed	38	48	3	3	3
			7. CUM one shunt cap tripped	39	48	3	3	4
	29 HS	N/A (Before the project is connected)	P0	8. System normal	38	52	20	20
130		9. System normal		36	52	6	6	7
28 HW	Winter Rating (MVA)			260.8	142.7	286.8	286.8	300.0

	N/A (Before the project is connected)	P0	10. System normal	28	42	18	18	21
	130		11. System normal	26	42	6	6	7

Note: N/A means not applicable.

5.1.2 Steady State Voltage Analysis

With the connection of the IC's project, the voltage performance under system normal condition and single contingencies is acceptable for all the three load conditions (29LS, 29HS, 28HW). Table 5-2 shows a summary of steady-state voltage performance under various system conditions and contingencies.

No voltage violation is observed for these contingencies.

Table 5-2: Summary of Steady-State Voltage Study Results

Case	IC's Power Injection at POI (MW)	Contingency		Bus Voltage (pu)			
		Cat.	Cases & Description	NIC 138	P65T 138	SCO 138	CUM 138
2029 LS	N/A (Before the project is connected)	P0	1. System normal	1.02	1.02	1.02	1.02
	130		2. System normal	1.02	1.03	1.02	1.02
	65		3. System normal	1.03	1.03	11.02	1.02
	0		4. System normal	1.03	1.03	1.02	1.02
	130	P1	5. 1L251_B tripped	1.02	1.03	N/A	N/A
			6. 1L251 Series Capacitor bypassed	1.02	1.02	1.02	1.02
			7. CUM one shunt cap tripped	1.02	1.03	1.02	1.02
2029 HS	N/A (Before the project is connected)	P0	8. System normal	1.02	1.02	1.02	1.02
	130		9. System normal	1.02	1.03	1.02	1.02
2028 HW	N/A (Before the project is connected)	P0	10. System normal	1.03	1.02	1.02	1.02
	130		11. System normal	1.02	1.03	1.02	1.02

Note: N/A means not applicable

5.1.3 Reactive Power Capability Evaluation

The BC Hydro TIR requires IBR power plant to have the dynamic reactive power capability at a minimum of +/- 33% of its MPO at the high voltage side of the IC's

switchyard over the full MW operating range.

Based on the PSS/E power flow data submitted by the IC, the proposed generating project would be capable of meeting the BC Hydro's reactive capability requirement at the plant's maximum MW output.

Furthermore, the BCH TIR requires the IC's project to provide sufficient reactive power capability over full MW operating range including at zero MW output level. According to the IC-provided reactive capability curve and shunt capacitor data, the proposed inverter has sufficient reactive power capability at zero MW output, which needs to be re-confirmed if the IC's project proceeds further.

5.1.4 Anti-Islanding Requirements

If 1L251_A between NIC and P65T is open at either end, the IC's project may be inadvertently islanded with the existing BC Hydro loads, which is not allowed. A direct transfer trip (DTT) from NIC to P65T is required to isolate the Mount Thynne Wind Project for protective and unintentional tripping of 1L251_A at NIC or P65T.

In addition, the IC is required to install anti-islanding protection within its facility to disconnect the IC's project from the grid when an inadvertent island with the local load forms.

5.2 Fault Analysis

The short circuit analysis in the FeS is based upon the latest BC Hydro system model, which includes the generating facility information and associated impedance data provided by the IC. A more detailed study will be performed at the system impact study stage if needed.

5.3 Stations Requirements

A new outdoor 138 kV, 3-circuit breaker ring bus switching station (refer to as "P65T") will be built at the POI, close to the existing 138 kV transmission line 1L251. The existing transmission line 1L251 will be cut and looped in to P65T, and 138 kV line from Mount Thynne Wind Project will be terminated at the P65T.

The study has concluded following substation work:

- Acquire adequate property for a new substation close to the existing

transmission line 1L251.

- Construct a new outdoor 138 kV, 3-circuit breaker ring bus switching substation. Refer to the one-line sketch in Appendix B for details.

5.4 Transmission Line Requirements

It is required to furnish and install 48-strand fibre optic cable on 1L251 structures from 1L251 series capacitor project to P65T for telecommunication. The length is approximately 38 km. Structure replacement and mid span structures may be required due to fibre addition.

5.5 Protection & Control Requirements

BC Hydro will provide line protections for 138 kV line 1L251_A, 1L251_B and 1L251_C (BCH end only). As part of the line protection replacements for each of the three lines, telecommunication facilities will be required to accommodate the new protection schemes.

The IC is required to provide the following for the interconnection of Mount Thynne Wind Project:

- Entrance protection that complies with the latest version of the “60 kV to 500 kV BC Hydro Technical Interconnection Requirements for Power Generators.”
- Provide two SEL-411L-1 relays (firmware and options specified by BC Hydro) at the entrance of P65 to provide protection coverage for 1L251_C. BC Hydro P&C Planning will provide core protection settings for these relays to protect transmission line 1L251_C during a transmission line fault. Non-core protection such as local breaker failure, auto-reclosing, backup protection for station elements will not be provided by BC Hydro P&C Planning.
- The IC is responsible for NERC PRC-related tasks, settings to compliance standards within their facilities.
- The IC is responsible for providing a communications link for remote interrogation of the PPIS equipment by BCH servers.
- Provide anti-islanding protection as stated in Section 5.1.

5.6 Telecommunications Requirements

BC Hydro performed a high-level feasibility assessment of a telecom solution to meet the following requirements.

Teleprotection Requirements for Telecom

- Provide WECC Level three (3) 64 kbps synchronous circuits between NIC and P65T for 1L251_A PY DIGITAL TELEPROT” and NIC-P65T 1L251_A SY DIGITAL TELEPROT”. Physical interface shall be C37.94 optical over multimode fibre using ST connectors.
- Provide WECC Level three (3) 64 kbps synchronous circuits between P65T and P65P for 1L251_C PY DIGITAL TELEPROT and 1L251_C SY DIGITAL TELEPROT. Physical interface shall be C37.94 optical over multimode fibre using ST connectors.

Tecontrol Requirements for Telecom

- Provide P65T SCADA circuit, minimum speed 9.6 kbps.
- Provide P65T REMACC circuit.
- Provide P65P SCADA circuit.

Other Requirements for Telecom

- None identified.

Certain assumptions were made for determining a potential telecom solution. Details of the telecom solution (e.g. assumptions made, alternatives investigated and work required for BCH and the IC) would be provided at the next study stage.

6 Cost Estimate and Schedule

The non-binding good faith estimated cost and time to construct the Network Upgrades required to interconnect the proposed project will be provided in a separate letter to the IC.

7 Conclusions

To interconnect the Mount Thynne Wind Project and its facilities to the BCH Transmission System at the POI, this Feasibility Study has identified the following conclusions and requirements:

1. A new 138 kV switching station (referred to as “P65T”) on 1L251 is required at the proposed POI for interconnecting the IC’s generating project to the BCH system.
2. The connection of Mount Thynne Wind Project does not cause any performance violation (i.e. thermal overload, voltage performance violation or voltage stability concern) under system normal and single contingency conditions.
3. In addition to the project’s entrance protection and 1L251_C line protection, the IC is required to install anti-islanding protection within its facility to detect and disconnect itself from the BC Hydro transmission system if an inadvertent island with the local loads forms. In addition, a direct transfer trip (DTT) from NIC to the new switching station P65T is required to disconnect the project for protective and unintentional tripping of 1L251_A at NIC or P65T.
4. It is required to furnish and install 48-strand fibre optic cable on 1L251 from 1L251 series capacitor project to P65T for telecommunication. The length is approximately 38 km. Structure replacement and mid span structures may be required due to fibre addition.
5. The new line 1L251_A will become part of BC Hydro BES and need to be compliant with applicable NERC MRS requirements. The IC’s line 1L251_C may be a BES element as well. The new line 1L251_B (P65T-CUM) will remain as a non-BES line.
6. BCH will provide line protections for 1L251_A, 1L251_B and 1L251_C (BCH end only) protections. As part of the line protection replacements for each of the three lines, telecommunication facilities will be required to accommodate the new protection schemes.

The above conclusions are made based on the IC's input data and study assumptions listed in Section 4, which represent the best available information on

May 21, 2024.

A non-binding good faith cost for required network upgrades and estimated schedule for construction are included in a separate letter to the IC.

Appendix A

Plant Single Line Diagram Used for Power Flow Study

Figure A-1 shows Mount Thynne Wind Project single line diagram used for power flow study.




Figure A-1: Mount Thynne Wind Project Single Line Diagram for Power Flow Study.

As seen in the diagram, Mount Thynne Wind Project has one main power transformers. In the project, there are four (4) feeders connecting 26 wind turbines to the collector station, and three 15 Mvar switchable shunt capacitors.

Appendix B

One-Line Sketch for New Switching Station

Figure B-1 shows the Stations Planning One-Line Sketch for the New Switching Station P65T.




Figure B-1: Stations Planning One-Line Sketch for the New Switching Station P65T.